

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7315-0075:197 Page 1 of 1

**CATEGORY:** Power Units

**LISTEE:** Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653  
Contact: Brian Reynolds (203) 484-1200

**DESIGN:** Model FCPS-2404 Remote Notification Circuit Expander/Battery Charger. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120VAC, 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Unit shall provide the 24 hrs battery backup as required per NFPA 72, 1996 Edition.

**MARKING:** Listee's name, product designation, electrical rating and UL label.

**APPROVAL:** Listed as Remote Notification Circuit Expander/Battery Charger for use with separately listed electrically and functionally compatible fire alarm control units.

08-28-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**APRIL 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager